

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50433

1. Consultant: HALEY AND ALDRICH, INC. Client: _____
 1. OWNER: _____ ADDRESS AT WELL LOCATION: THE BOEING CO.
 MAILING ADDRESS: 6200 East 14th St., Suite A200 Tucson, Arizona 85711 6633 Canoga Avenue, D/393 T487
Canoga Park, California 01303
 2. LOCATION: NE 1/4 SE 1/4 Sec. 18 T. 22N N/S R. 22 E Washoe County _____
 PERMIT NO. R-422A Well C-21A 77-310-04 Area C. 2700 Right Hand Canyon Road
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other: TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand with silt, light brown, fine sand, poorly graded, slightly moist, small percentage of fine gravel		0	15	15
Sand with gravel, light brown, fine to med. sand, poorly graded, slightly moist, becoming more moist at 20 feet, increasing in silt and clay content at 29 feet		15	34	19
Tuff, red, moderately welded, biotite and feltspar phenocrysts, some yellow tuff fragments in cuttings		34	40.2	6.2
<i>Plugged by well log No. 116282</i>				

8. WELL CONSTRUCTION
 Depth Drilled 40.2 Feet Depth Cased 40.2 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 1/2 Inches To 0 Feet 40.2 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 3/4"</u>	<u>PVC</u>	<u>sch 80</u>	<u>0</u>	<u>20.2</u>

PVC end cap, compression cap, centralizers, 8"x5' locking monument
 Perforations:
 Type perforation factory sawed slot
 Size perforation 0.020
 From 20.2 feet to 40.2 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: _____
 Depth of Seal 0-13.5 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Bentonite seal: 13.5 - 14.5
 Gravel Packed: Yes No SRI #8 sand
 From 14.5 feet to 40.2 feet

9. WATER LEVEL
 Static water level dry feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality not known

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. Box 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date December 10, 2002

Date started 11-20-2002, 20 _____
 Date completed 11-21-2002, 20 _____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
No test			