DIVISION OF WATER RESOURCES

10N/24 - 13 or 14

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 11174
Permit No.
Basin Carson Val CARD

1. OWNER G. D. Johnson ADDRESS Wellington Nevada Highway 23

2. LOCATION ¼ ¼ Sec. 13-14 T. 10N. 24 E N/S R. E. Douglas County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT-gravel (Brown)		0'	20'	20'
SILT-Sand-Gravel (Gray)		20	60'	40'
SILT Sand gravel Brown		60	70'	10'
Clay Rock Brown		70'	80'	10'
Clay Rock yellow		80'	95'	15'
Clay-Rock-gravel gray		95'	108'	13'
Hit Water @	108'		108'	
Enough to drill with Sand-Gravel		108'	150'	42'

Date started 6/24, 1970
Date completed 7/20, 1970

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	30		

BAILER TEST
G.P.M. 15 Draw down 0 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 5/8 inches Total depth feet
Casing record
Weight per foot 188 Thickness 1/4

Diameter	From	To
12 inches	0 feet	50 feet
8 inches	50 feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation Torch
Size perforation 1/8" x 6" - 3 around
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 102 Feet below land surface 102
Flow G.P.M.
Water temperature Cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Doyle H. Wakeling
Address 1350 Kirman ave
Nevada contractor's license number 10188
Nevada driller's license number 575
Signed Doyle H. Wakeling
Date Aug 15 1970

USE ADDITIONAL SHEETS IF NECESSARY

5471