DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

#6

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 1129
Permit No. 25967
Basin Lemmon Val
27239

1. OWNER Lemmon Valley Land Co ADDRESS Lemmon and Hydrauliek St Lemmon Valley Nev.

2. LOCATION NW ¼ SW ¼ Sec. 26 T. 21 N/S R. 19 E. Washoe County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	13	13
Sand		13	14	1
Clay		14	30	16
Sand		30	31	1
Clay		31	74	43
Sand		74	76	2
Layers - Sand & Clay		76	89	13
Clay		89	95	6
Sand		95	97	2
Clay		97	118	21
Coarse Sand		118	123	5
Clay		123	132	9
Sand		132	134	2
Clay		134	145	11
~~Layers, Sand & Clay~~				
Layers, Sand & Clay		145	212	67
Cobbles & Clay		212	225	13
Cemented D.G.		225	300	75
Clay		300	304	4
Clay & Gravel		304	315	13
Coarse Sand & Fine Grav		315	339	24
Layers, Sand, Grav & Clay		315	407	92
Sand & Fine Gravel		407	438	31
Granite		438	446	8

Date started June 16, 1976
Date completed Oct 30, 1976

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	346	88½	24

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION 32" 50 -
Diameter hole 24 inches Total depth 438 feet
Casing record
Weight per foot 33 Thickness 250

Diameter 250	From	To
26 inches	+1 feet	50 feet
12 inches	+1 feet	438 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal ..... feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 0 feet to 438 feet

Perforations:
Type perforation Machined
Size perforation 1/8 x 3
From 111 feet to 130 feet
From 162 feet to 191 feet
From 215 feet to 237 feet
From 261 feet to 438 feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 15 Feet below land surface
Flow ..... G.P.M.
Water temperature 60 ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Enloe Drilling Co
Address 1450 Valley View Drive Carson City
Nevada contractor's license number 4739
Nevada driller's license number 249
Signed [signature]
Date Oct 30 - 70

USE ADDITIONAL SHEETS IF NECESSARY

5471