

OFFICE USE ONLY
Log No. 11373
Permit No. _____
Basin Carson Desert

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER T. J. Carpenter ADDRESS 150 Schindler rd. Fallon, Nev 89406
Well #2
2. LOCATION SW 1/4 SE 1/4 Sec. 9 T. 18 N/S R. 28 E. Churchill County
PERMIT NO. _____

3. TYPE OF WORK
New Well Recondition
Deepen Other
4. PROPOSED USE
Domestic Irrigation Test
Municipal Industrial Stock
5. TYPE WELL
Cable Rotary
Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>7'</u>	
<u>clay</u>		<u>7</u>	<u>12'</u>	
<u>sandy fine water</u>		<u>12'</u>	<u>14'</u>	
<u>clay</u>		<u>14</u>	<u>15'</u>	
<u>fine sand</u>		<u>15'</u>	<u>17'</u>	
<u>course sand</u>		<u>17'</u>	<u>22'</u>	
<u>fine sand</u>		<u>22</u>	<u>24'</u>	
<u>course sand</u>		<u>24</u>	<u>29'</u>	
<u>course clay</u>		<u>29'</u>		

8. WELL CONSTRUCTION
Diameter hole 8 3/4 inches Total depth 29' feet
Casing record _____
Weight per foot _____ Thickness _____
Diameter From To
8 3/4 inches 0 feet 29' feet
_____ inches _____ feet _____ feet
Surface seal: Yes No Type Concrete
Depth of seal 12' feet
Gravel packed: Yes No
Gravel packed from _____ feet to _____ feet
Perforations:
Type perforation torch
Size perforation 1/16
From 23 feet to 29 feet
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 12' Feet below land surface
Flow _____ G.P.M.
Water temperature cold ° F. Quality good

Date started 1-26- 19 71
Date completed 1-29- 19 71

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Art Van Kessel
Address 845 McLean St Fallon, Nev
Nevada contractor's license number _____
Nevada driller's license number 534
Signed Art Van Kessel
Date 2/5/71