

WELL DRILLERS REPORT

Please complete this form in its entirety.



1. OWNER Murton Bauman ADDRESS PA Branch

2. LOCATION Supply To - only - SE 1/4 Sec 3 T. 21 N/S R. 54 E County

PERMIT NO. 10571

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input checked="" type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard Black Rock		450	478	28
Cemented Gravel		478	533	
Hard Black Rock		533	548	
Cemented Gravel		548	566	
Black SAND	✓	566	586	20
Black Rock Fractured		586	618	
"		618	649	
Sticky Gray Clay		649	652	03

8. WELL CONSTRUCTION

Diameter hole 12 8/8" inches Total depth 652 feet

Casing record 8 5/8" inches

Weight per foot 10.75 Thickness 1099e

Diameter	From	To	Thickness
<u>8 7/8" inches</u>	<u>490</u> feet	<u>652</u> feet	<u>162</u> feet
<u>16" inches</u>	<u>0</u> feet	<u>201</u> feet	<u>201</u> feet
<u>14" inches</u>	<u>180</u> feet	<u>450</u> feet	<u>270</u> feet
<u>8" inches</u>	<u>440</u> feet	<u>652</u> feet	<u>212</u> feet

Surface seal: Yes  No  Type Cement

Depth of seal 50 feet

Gravel packed: Yes  No

Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet

Perforations:

Type perforation Torch Cut

Size perforation 14" x 10" 3 Rounds

From 60 feet to 652 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED

APR 13 1971

DIV. OF WATER RESOURCES  
BRANCH OFFICE  
LAS VEGAS, NEVADA

Date started 6-11- 19 70

Date completed 2-10 19 71

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>1800</u>	<u>180</u>	<u>24 hrs -</u>

BAILER TEST

G.P.M. ....	Draw down.....feet	.....hours
G.P.M. ....	Draw down.....feet	.....hours
G.P.M. ....	Draw down.....feet	.....hours

9. WATER LEVEL

Static water level.....Feet below land surface.....

Flow.....G.P.M.....

Water temperature.....° F. Quality.....

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Tom Floyd Pump & Drilling

Address PO Box 157 PA Branch Nev

Nevada contractor's license number 7479

Nevada driller's license number 476

Signed Tom Floyd

Date 4/12/71