DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 11554
Permit No.
Basin Carson Val CARO

1. OWNER JAMES J NEWMAN ADDRESS 604 WASHINGTON
CARSON CITY - NEV
LOT 5 - SARATOGA HIEGHTS SUBDIVISION -

2. LOCATION ¼ ¼ Sec. T. N/S R. E. DOUGLAS County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	15	15
CLAY		15	26	11
SAND + GRAV		26	46	20
SANDY CLAY		46	62	16
SAND		62	92	30

Date started Feb 8, 1971
Date completed Feb 12, 1971

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	20	20	4

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 92 feet
Casing record
Weight per foot 13 Thickness 1.88

Diameter	From	To
6 5/8 inches	21 feet	92 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 45 FT feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 92 feet

Perforations:
Type perforation Milled
Size perforation 1/8 x 3
From 60 feet to 92 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 12 Feet below land surface
Flow G.P.M.
Water temperature 69 ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Enlet Drilling Co
Address 1450 Valley View Drive
CARSON CITY
Nevada contractor's license number 4739
Nevada driller's license number 249
Signed [signature]
Date June 14 1971

USE ADDITIONAL SHEETS IF NECESSARY

5471