RECEIVED
DIVISION OF WATER RESOURCES
MAY 25 1971
DIV. OF WATER RESOURCES
BRANCH OFFICE
LAS VEGAS, NEVADA

Nye

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 11558
Permit No.
Basin

1. OWNER Spring Meadows ADDRESS P. O. Box 38, Lathrop Wells, Nevada

2. LOCATION SE ¼ SE ¼ Sec. 16 T. 17S N/S R. 50 E. County
PERMIT NO. 23044

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	18	18
Gray Clay		28	37	9
Gray Clay		37	50	13
Red Clay		50	67	17
Gray Clay		67	115	48
Lime Stone		115	180	65
Gray Clay		180	210	30
Gray Limestone		210	230	20
Blue Clay		230	240	10
Gray-Green Material		240	250	10
Conglomerate		250	270	20
Gray Limestone		270	285	15
Green Limestone		285	295	10
Boulders		295	300	5
Gray Clay		300	330	30
Red Clay		320	335	5
Gray Clay		335	390	55
Red Sandy Clay		390	395	5
Red Clay		395	410	15
Grey Clay		410	445	35
Red Clay		445	455	10
Red Clay & Limestone		455	470	15
Gravel and Sand		470	495	25
Red Clay and Sand		495	500	5

Date started March 12, 19 71
Date completed May 13, 19 71

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1,000	250	220	12

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 16" inches Total depth 500 feet
Casing record 300'
Weight per foot 55 Thickness ½"

Diameter	From	To
16 inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☒ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Slot
Size perforation 3/16 x 3"
From 0 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level Feet below land surface 16
Flow G.P.M. 250
Water temperature 61 ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Walter N. Bristow
Address P. O. Box 38, Lathrop Wells, Nevada 89020
Nevada contractor's license number
Nevada driller's license number 640
Signed Walter N. Bristow
Date May 18, 1971

USE ADDITIONAL SHEETS IF NECESSARY

5471