STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110009
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64854

1. OWNER JOSE URIBE
MAILING ADDRESS 270 S. 2ND STREET
ELKO, NV 89801-3617

ADDRESS AT WELL LOCATION ROCKLAND DRIVE
(CUSTOMER LOT #4)
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION SW ¼ NE ¼ Sec 7 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09B-066
Issued by Water Resources Parcel No.

Latitude 40.847927° N
Longitude 115.820122° W
NAD 27 (TM)
UTM E 11T 0599461 ☒ NAD 27
N 4522334 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	1	1
GRAVEL w/SAND & CLAY		1	30	29
COMPACTED GRAVEL AND		30	150	120
BOULDERS				
TAN & GREY GRAVEL		150	280	130
RED/BROWN PEDIMENT		280	360	80
GREY PEDIMENT		360	400	40
GREEN & RED COURSE		400	480	80
PEDIMENT GRAVEL				
GREEN VOLCANIC TUFT	X	480	580	100
WATER ZONE AT 560'				

Date started: 17-Dec, 20 09
Date completed: 22-Dec, 20 09

9. WELL CONSTRUCTION
Depth Drilled 580 Feet Depth Cased 580 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	580	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	580

Perforations:
Type of perforation MACHINED MILL SLOT
Size of perforation 3/16" X 3", 6 ROWS
From 560 feet to 580 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 4 to 16 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 580 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 16 to 50 ☐ Pumped ☒ Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 328 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 62 °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
125 PSI @	17		3
825 CFM			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1653
Signed Jerry C. Bener (By driller performing actual drilling on site or contractor)
Date 12/22/2009

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY