STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110010
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64855

1. OWNER JOSE URIBE
MAILING ADDRESS 270 S. 2ND STREET
ELKO, NV 89801-3617

ADDRESS AT WELL LOCATION PRIVATE ROAD ACCESS BETWEEN CATTLE DRIVE & ROCKLAND DRIVE
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION SE ¼ NE ¼ Sec 7 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09B-067
Issued by Water Resources
Parcel No.

Latitude 40.847915°N
Longitude 115.818016°W
(NAD 27 TP)
UTM E 11T 0599639 ☒ NAD 27
N 4522335 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	1	1
GRAVEL w/SAND & CLAY		1	40	39
FINE GRAVEL & BOULDERS		40	120	80
GREY PEDIMENT GRAVEL		120	230	110
RED PEDIMENT		230	340	110
GREY & TAN PEDIMENT		340	380	40
GREY/GREEN VOLC TUFT		380	460	80
TAN & GREY PEDIMENT	480	460	480	20
GREEN VOLCANIC TUFT		480	500	20

Date started: 22-Dec, 20 09
Date completed: 24-Dec, 20 09

9. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	500	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13.0	.188	+2	500

Perforations:
Type of perforation MACHINE MILL SLOT
Size of perforation 3/16" X 3", 6 ROWS
From 480 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 3 to 16 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 500 ☐ Pumped ☒ Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: ☒ Yes ☐ No 16 to 50 ☐ Pumped ☒ Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 280 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 62 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
125 PSI @	20		2.5
825 CFM			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC.
Contractor
Address P. O. BOX 850
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1653
Signed Jerry C. Bener
By driller performing actual drilling on site or contractor
Date 1/20/2010

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY