

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. *61758*
 ADDRESS AT WELL LOCATION *207 East Grant Ave.*
Ely, NV 89301

1. OWNER *Jesse Murdock* ADDRESS AT WELL LOCATION *207 East Grant Ave.*
 MAILING ADDRESS *207 East Grant Ave.* *Ely, NV 89301*
 2. LOCATION NE *1/4* NW *1/4* Sec *23* T *16* N/S R. *63* E *White Pine* County
 PERMIT NO. *33203* *10-500-07* *Pearce*
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 ~~Domestic~~ Municipal/Industrial Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandonment Procedures				
Baroid Holeplug Chips		174	104	70
Cement Grout		104	Surface	104
NOTE: Above Well was drilled by Jim Schooler (Unable to locate a log)				
NOTE: Enclosed is copy of new Well log; drilled by Christiansen Drilling, Inc. replacement well under well log #107938				
<i>39.243°N 114.853°W NAD27 0.0.</i>				

8. WELL CONSTRUCTION
 Depth Drilled *174* Feet Depth Cased *Unknown* Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8	Unknown			

Perforations:
 Type perforation *Unknown*
 Size perforation *Unknown*
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal *Unknown* Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No *Unknown*
 From _____ feet to _____ feet

Date started *January 5*, 20*09*
 Date completed *January 6*, 20*09*

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<i>80</i>	<i>2.7</i>	<i>26</i>

9. WATER LEVEL
 Static water level *104* feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature *Cold* °F Quality *Muddy*

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name *Christiansen Drilling, Inc.* Contractor
 Address *557 Ely Ave.* Contractor
Ely, NV 89301
 Nevada contractor's license number *14790*
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller *1793*
 Signed *Rick Lewis By Harold O. Christiansen*
 By driller performing actual drilling on site or contractor
 Date *January 22, 2009*