STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110053
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60368

1. OWNER James Myers
MAILING ADDRESS 1155 Clyde Court Fallon NV
SE

ADDRESS AT WELL LOCATION 1150 Clyde Court
Fallon, NV
Subdivision Name: Garden City Heights County: Churchill

2. LOCATION se ¼ ¼ Sec 22 T 19N N/S R 28 E
PERMIT/WAIVER No. 010-212-01
Issued by Water Resources Parcel No.

Latitude 39.49178
Longitude 118.82084
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	18	18
Brown clay & sand		18	26	8
DG	x	26	88	62
DG gravel	x	88	115	27
Black sandy clay	x	115	120	5

39.492°N NAD 27 D.D.
118.820°W

2009 JUN -3 AM 11:59
STATE ENGINEER

Date started: 21-Apr, 20 09
Date completed: 22-Apr, 20 09

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	20
6 5/8	4	SDR21	20	120

Perforations:
Type of perforation grinder cut
Size of perforation .045" x 3"
From 105 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☒ Cement Grout	0 to 100		☒ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 120 ☐ Pumped ☐ Poured
Type: 3/8" washed pea gravel
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 19 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blain Drilling (Contractor)
Address Po Box 1255 (Contractor)
Carson City NV 89702
Nevada contractor's license number issued by the *State Contractor's Board* 46498
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2167
Signed (By driller performing actual drilling on site or contractor)
Date April 25-09

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY