REPORT NO. A9.10

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

LOG NO. 110078
PERMIT NO.
BASIN 092B

NOTICE OF INTENT NO. 63737

1. OWNER Washoe County Dept of Water Resources
MAILING ADDRESS 4930 Energy Way, Reno NV 89502

ADDRESS OF WELL 525 Oregon
Reno, NV 89506

2. WELL LOCATION ~~SW~~ NW 1/4 NW 1/4 SEC. 15 T 21 R 19 E Washoe COUNTY
PERMIT NO PARCEL NO 080-386-03 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Mud

6. LITHOLOGIC LOG

| MATERIAL | STRATA | FROM | TO | THICKNESS |
|---|---|---|---|---|
| | | | | |
| 39.691°N NAD27 D.D. | | | | |
| 119.844°W | | | | |

Notes: **WGS-84 GPS: Latitude: N39 41.474 Longitude: W119 50.712. Casing has seal. Run Bailer to 390'. Perforated Casing from 236' to 390'. Pumped Bentonite Grout from 390' to 20'. Pumped Neat Cement from 20' to Surface. Original Well Log #30048**

Date Started 03/04/2009 Date Completed 03/04/2009

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [ ] Air Develop

| | GPM | DRAWDOWN | TIME (HRS) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION

Depth Drilled _____ Depth Cased _____

HOLE DIAMETER (BIT SIZE)
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size OD | Weight/Ft | Wall Thickness | From | To |
|---|---|---|---|---|
| 6 5/8" | 10.78 | .156 | +2' | 390' |
| | | | | |
| | | | | |
| | | | | |

PERFORATIONS:
Type Perforation _____ Size Perforation _____
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth _____
PLACEMENT METHOD: [ ] Pumped [ ] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [ ] Yes [ ] No
From _____ Feet to _____ Feet

9. WATER LEVEL
Static Water Level 286 Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature _____ F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502
NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2362
Signed Roger M Thuel
By driller performing actual drilling on site or contractor
Dated March 12 2009