STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110096
Permit No.
Basin 031

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62884

1. OWNER STEVE FOSTER
MAILING ADDRESS P. O. BOX 2104
LOVELOCK, NV 89419

ADDRESS AT WELL LOCATION 12005 BROOKSCANYON ROAD
LOVELOCK, NV 89419
Subdivision Name: HUMBOLT ESTATES County: PERSHING

2. LOCATION SW ¼ SE ¼ Sec 3 T 39N N/S R 33 E
PERMIT/WAIVER No. 010-040-16
Issued by Water Resources Parcel No.

Latitude 40.487833°N
Longitude 118.253627°W
NAD 27 (TH)
UTM E 393752 ☒ NAD 27
N 4482448 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BOULDERS/COBBLES		1	30	29
COBBLES/MC/GRAVEL		30	150	120
BROWN CLAY/SAND STRINGS		150	200	50
MC GRAVELS,SANDS		200	430	230
RED CLAY		430	450	20
CEMENTED GRAVELS		450	550	100
MC GRAVELS,SANDS	X	550	756	206

Date started: 19-Jan 20 10
Date completed: 29-Jan 1/19 (12) 20 10

9. WELL CONSTRUCTION
Depth Drilled 756 Feet Depth Cased 756 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6	Inches	50	Feet	756	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	756

Perforations:
Type of perforation MACHINE SLOT
Size of perforation .080
From 670 feet to 686 feet
From 736 feet to 756 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 548.7 feet below land surface
Artesian Flow: G.P.M. 10 P.S.I.
Water Temperature: COOL °F
Quality: UNTESTD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	10	AIR LIFT	1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP.
Contractor
Address P. O. BOX 888
Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the *State Contractor's Board* 11752
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2099
Signed
By driller performing actual drilling on site or contractor
Date 23-Jan-10

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY