STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110138
Permit No.
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62530

1. OWNER Param Investment LLC
MAILING ADDRESS 18553 Spicer Lake Court Reno, NV

ADDRESS AT WELL LOCATION Facility ID - 4-000502 GMAS-1
4600 N Virgina Street Reno, NV
Subdivision Name: County: Washoe

2. LOCATION NW ¼ SW ¼ Sec 26 T 20N N/S R 19 E
PERMIT/WAIVER No. 003-091-18
Issued by Water Resources Parcel No.

Latitude 39.570379°N
Longitude 119.824002°W
Lat/Long 27 NAD
UTM N 4383878 E 0257333
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gray Gravel		0	14	14
Light Gray Gravel with Silt/Clay		14	36	22
Light Brown Clay with Silt/Gravel		36	46	10
Light Brown Gravel with Silt/Clay		46	59	13
Black/Brown Clay with Silt/Gravel		59	76	17
Light Brown/White Clay with Silt/C		76	86	10
Gray Clay with Silt/Gravel		86	92	6

Date started: 28-Oct, 20 09
Date completed: 29-Oct, 20 09

9. WELL CONSTRUCTION
Depth Drilled 92 Feet Depth Cased 92 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
2	Inches	0	Feet	92	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	70

Perforations:
Type of perforation Slot
Size of perforation .020
From 70 feet to 90 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal ☒ Yes ☐ No
☒ Neat Cement 0 to 64 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 67 to 92 ☐ Pumped ☒ Poured
Type: #3 Sand
Bentonite Chips: ☒ Yes ☐ No 64 to 67 ☐ Pumped ☒ Poured
Type: Medium

7. Water Level
Static water level: 47 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling, L.P. (Contractor)
Address 3632 Omec Circle (Contractor)
Rancho Cordova, CA 95742
Nevada contractor's license number issued by the State Contractor's Board 0073966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1977
Signed (By driller performing actual drilling on site or contractor)
Date 12-Feb-10

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY