STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110151
Permit No.
Basin Ø87

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65172

1. OWNER Farhad Nejabat
MAILING ADDRESS 1675 Victorian Ave.
Sparks, NV

ADDRESS AT WELL LOCATION Facility ID 4-000327 MW-1
1675 Victorian Ave. Sparks, NV
Subdivision Name: County: Washoe

2. LOCATION SE ¼ SW ¼ Sec 5 T 19N N/S R 20 E
PERMIT/WAIVER No. 032-125-26
Issued by Water Resources Parcel No.

Latitude N39°32'05.95" UTM E ☐ NAD 27
Longitude W119°45'54.00" N ☒ NAD 83/WGS 84
39.535675°N 119.763977°W NAD 27 (T2)

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well graded sand with cobbles		0	5	5
Well graded sand with cobbles		5	11	6
Poorly graded sand with cobbles		11	16	5
Boulder		16	17	1
Well graded sand with gravels		17	20	3
Clay & clayey gravel		20	24	4
Well graded gravel with cobbles		24	33	9

Date started: 20-Jan, 20 10
Date completed: 21-Jan, 20 10

7. *Water Level*
Static water level: 18 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. *WELL CONSTRUCTION*
Depth Drilled 33 Feet Depth Cased 28 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7	Inches	0	Feet	33	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 40	0	6

Perforations:
Type of perforation Slot
Size of perforation .020
From 6 feet to 28 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 4 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 6 to 33 ☐ Pumped ☒ Poured
Type: #3 Sand
Bentonite Chips: ☒ Yes ☐ No 4 to 6 ☐ Pumped ☒ Poured
Type: Medium

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling, L.P.
Contractor
Address 3632 Omec Circle
Contractor
Rancho Cordova, CA 95742
Nevada contractor's license number issued by the *State Contractor's Board* 0073966
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-1977
Signed
By driller performing actual drilling on site or contractor
Date 2/16/10

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY