STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110177
Permit No.
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63641

1. OWNER TNT Farms (Grass Pivot #2)
MAILING ADDRESS 9200 Beechcraft Blvd
Winnemucca, Nevada 89445

ADDRESS AT WELL LOCATION Donald Lane/Grass Valley Rd
Winnemucca, Nevada 89445
Subdivision Name: County: Humboldt

2. LOCATION NE ¼ SW ¼ Sec 25 T 35N N/S R 37 E
PERMIT/WAIVER No. 20091
Issued by Water Resources Parcel No

Latitude N40*52.747
Longitude W117*45.969
40.879213°N 117.765187°W NAD 27 (72)
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other ABANDONMENT

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well ABANDONMENT				
(original log 8691) 1965				
Abandoned 16"well that was				
caved in to 280 ft. Perforated				
well from 5 ft. to 120 ft. with a				
Holt air star perforator and TH60				
drill rig - perf 8 rows of cuts.				
Set 270 ft. 2.5" triem pipe and				
pumped 253 (50#) bags of				
Gropher grout in well from				
20 ft to 280 ft. We pumped				
2 cy. of concrete in the top of well				
Casing was cut 5 ft. below ground				

Date started 30-Oct , 20 08
Date completed 31-Oct , 20 08

9. WELL CONSTRUCTION
Depth Drilled 394 Feet Depth Cased 393 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
16	Inches	0	Feet	394	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16			0	176
14			171	393

Perforations:
Type of perforation Mill
Size of perforation ½" x 2"
From 110 feet to 393 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 95 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources
Contractor
Address 4975 W. Winnemucca Blvd
Contractor
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the *State Contractor's Board* 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1713
Signed
By driller performing actual drilling on site or contractor
Date 2/25/10

(Rev 05-06)

USE ADDITIONAL SHEETS IF NECESSARY