STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110205
Permit No. 21236
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33575

1. OWNER David Love
MAILING ADDRESS PO Box 187
Caliente Nv. 89008

ADDRESS AT WELL LOCATION 2315 South U.S. 93
Panaca Nv
Subdivision Name: County Lincoln

2. LOCATION NE ¼ SE ¼ Sec 24 T 2 N R 67 E
PERMIT/WAIVER No. 21236 | 012 210 35
71389 Issued by Water Resources Parcel No.

Latitude 37° 45.467 N UTM E ☑ NAD 27
Longitude 114° 25.746 W N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☑ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, clay, gravel		0	82	82
Clay		82	119	37
Sand, gravel, cobbles	X	119	140	21
Sandy clay		140	185	45
Sand, gravel	X	185	193	8
Clay		193	225	32
Sand, gravel	X	225	247	22
Clay		247	260	13

MAR 18 2010

Date started: Sept 26, 20 09
Date completed: Sept 28, 20 09

7. Water Level
Static water level: 107.3 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Sept. 30	40		4 hrs

9. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	17	.250	0	20
6	SDR 17		20	260

Perforations:
Type of perforation: Factory screen
Size of perforation .032
From 160 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☑ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☑ Cement Grout 0 to 63 ☐ Pumped ☑ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☑ Yes ☐ No 63 to 260 ☐ Pumped ☑ Poured
Type: 3/8 washed gravel
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Anzalone Pumps
Contractor
Address 395 N. Beryl Hwy
Contractor
Beryl Ut. 84714
Nevada contractor's license number issued by the State Contractor's Board 0073603
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238
Signed Bryan Anzalone
By drill or performing actual drilling on-site or contractor
Date Nov. 3, 2009

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) Also Permit 71389

(C) 627