

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33206

1. OWNER JOHN & TERESA JACOBS ADDRESS AT WELL LOCATION LANDER ST.
 MAILING ADDRESS HCR 70 BOX 5620
AMARGOSA, NV 89020

2. LOCATION SE 1/4 SW 1/4 Sec. 2 T 18S N/S R 49E E NYE County
 PERMIT NO. _____ Issued by Water Resources 19-472-11 Parcel No. LITTLE NEVADA Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & CLAY		0	6	6
CALICHIE		6	34	28
SAND & CLAY		34	94	60
GRAVEL	WB	94	109	15
CALICHIE	WB	109	114	5
GRAVEL & CLAY		114	142	28
GRAVEL & SAND	WB	142	181	39
CLAY		181	200	19

UTM E 0551958
 UTM N 4029618

MAR 02 2010

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4" Inches	0	60
9 7/8" Inches	60	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	3.63	.280	0	200

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 x 3

From	To
140	200

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor

Address 1220 E MANSE RD Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed [Signature] By driller performing actual drilling on-site or contractor
 Date 3/1/2010

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)