STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110309
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35188

1. OWNER TUPR LLC
MAILING ADDRESS 1 Main St.
Las Vegas, NV 89101

ADDRESS AT WELL LOCATION 200 S. Main St
MW-8 Las Vegas, NV
Subdivision Name: County: Clark

2. LOCATION NW ¼ NW ¼ Sec 34 T 20S N/S R 61 E
PERMIT/WAIVER No. 13934101008
Issued by Water Resources Parcel No.

Latitude 36. 101222
Longitude 115. 085182
UTM E N
[x] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [x] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	2	2
Silty Clay		2	8	6
Sandy Clay		8	12	4
Caliche		12	13	1
Silty Clay		13	16	3
Caliche		16	18	2
Silty Clay		18	30	12
Clayey Sand		30	33	3

Date started: 9-Feb , 20 10
Date completed: 9-Feb , 20 10

9. WELL CONSTRUCTION
Depth Drilled 33 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	33	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		Sch 40	0	30

Perforations:
Type of perforation Factory Slotted
Size of perforation .010
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 13 to 33 [ ] Pumped [x] Poured
Type: #3 Montery Sand
Bentonite Chips: [x] Yes [ ] No 1 to 13 [ ] Pumped [x] Poured
Type: 3/4 Bentonite Chips

7. Water Level
Static water level: 14.44 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells (Contractor)
Address 570 Corinthian Way (Contractor)
N. Las Vegas, NV, 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2381
Signed (By driller performing actual drilling on site or contractor)
Date 3-3-10

(Rev. 06-08)

USE ADDITIONAL SHEETS IF NECESSARY