

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT**

**OFFICE USE ONLY**  
Log No. 110314  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

**PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 35188

1. OWNER TUPR LLC ADDRESS AT WELL LOCATION 200 S. Main St  
MAILING ADDRESS 1 Main St MW-13 Las Vegas, NV  
Las Vegas, NV 89101 Subdivision Name: \_\_\_\_\_ County: Clark

2. LOCATION NW 1/4 NW 1/4 Sec 34 T 20S N/S R 61 E Latitude 36.101436 UTM E  NAD 27  
PERMIT/WAIVER No. 13934101008 Longitude 115.085175 N  NAD 83/WGS 84  
*Issued by Water Resources* Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  Cable  Rotary  RVC  Air  Other  Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill		0	2	2
Sandy Clay		2	3	1
Caliche		3	5	2
Silty Clay		5	7	2
Sandy Clay		7	12	5
Silty Clay		12	13	1
Caliche		13	16	3
Silty Clay		16	18	2
Sandy Clay		18	19	1
Caliche		19	21	2
Silty Clay		21	25	4
Sandy Clay		25	29	4
Clayey Sand		29	32	3

9. WELL CONSTRUCTION

Depth Drilled 32 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>8</u> Inches	<u>0</u> Feet <u>32</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>		<u>Sch 40</u>	<u>0</u>	<u>30</u>

Perforations:

Type of perforation Factory Slotted

Size of perforation .010

From 10 feet to 30 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 8 to 32  Pumped  Poured

Type: #3 Monterey Sand

Bentonite Chips:  Yes  No 1 to 8  Pumped  Poured

Type: 3/4 Bentonite Chips

Date started: 12-Feb , 20 10

Date completed: 12-Feb , 20 10

7. Water Level

Static water level: 14.75 feet below land surface

Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water Temperature: \_\_\_\_\_ °F

Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>		

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WDC Exploration & Wells  
Contractor

Address 570 Corinthian Way  
Contractor

N. Las Vegas, NV, 89030

Nevada contractor's license number issued by the State Contractor's Board 0012852

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2381

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date 3-3-10