STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110362
Permit No. 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64659

1. OWNER Keith Cox
MAILING ADDRESS 12250 Jeppson Reno NV

ADDRESS AT WELL LOCATION 12250 Jeppson
Reno, NV
Subdivision Name: County: Washoe

2. LOCATION SW ¼ SE ¼ Sec 17 T 18N N/S R 20 E
PERMIT/WAIVER No. DOM10-062 44-320-32
Issued by Water Resources Parcel No.

Latitude N 39 25.310' UTM E ☐ NAD 27
Longitude W 119 45.636' N ☒ NAD 83/WGS 84
39.421922°N 119.759580°W NAD 27 (TM)

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	11	11
Small Gravel & brown clay		11	61	50
Fine gravel		61	118	57
Fine gravel & coarse black sand	X	118	128	10
Small gravel	X	128	145	17
Small gravel & brown clay	X	145	150	5

Date started: 1-Mar, 20 10
Date completed: 3-Mar, 20 10

9. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	150	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	150

Perforations:
Type of perforation Factory cut
Size of perforation 3/32" X 3"
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 102 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 102 to 150 ☐ Pumped ☒ Poured
Type: 3/8 washed pea gravel
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 41 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blain Drilling
Contractor
Address PO Box 1255 CC NV 89702
Contractor
Nevada contractor's license number issued by the *State Contractor's Board* 46498
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2167
Signed
By driller performing actual drilling on site or contractor
Date 8-Mar

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY