STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110371
Permit No.
Basin 048

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65183

1. OWNER Oliver Brescini
MAILING ADDRESS 353 Lower South Fork Unit 2
Spring Creek, NV 89815

ADDRESS AT WELL LOCATION Clark Ave & 3rd St
Spring Creek, NV 89815
Subdivision Name: Lucky Nugget County: Elko

2. LOCATION SE ¼ NW ¼ Sec 23 T 32N N/S R 55 E
PERMIT/WAIVER No. 027-036-008
Issued by Water Resources
Parcel No.

Latitude W115 44.836
Longitude N40 38.782
40.646367°N 115.447267°W

UTM E
N
[X] NAD 27
[ ] NAD 83/WGS 84
NAD 27

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Brown Clay		2	8	6
Brown Silt Stone		8	22	14
Gravel & Boulder/Sand Mix		22	36	14
Brown Silt Stone		36	80	44
Brown Silt Stone & Gravel Mix	80	80	120	40

Date started: Feb. 26, 20 10
Date completed: Feb. 27, 20 10

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type of perforation mill slot
Size of perforation 3/16 x 3
From 99 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 0 to 50 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 50 to 120 [ ] Pumped [X] Poured
Type: pea gravel
Bentonite Chips: [ ] Yes [ ] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 46 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		3

RECEIVED
2010 MAR 25 AM 11:39
STATE ENGINEERS OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name David Hersh
Contractor
Address P.O. Box 281166
Contractor
Lamoille, NV 89815
Nevada contractor's license number issued by the *State Contractor's Board* 73955
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1689
Signed
By driller performing actual drilling on site or contractor
Date 3-2-2010

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY