FINALIZED MM

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110391
Permit No.
Basin 103

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64708

1. OWNER STEVE POLLARD
MAILING ADDRESS # 9 DANA ST
SW CARSON CITY, NV 8706

ADDRESS AT WELL LOCATION # 9 DANA ST
CARSON CITY, NV 89706
Subdivision Name: Sierra View Est. County: Lyon

2. LOCATION ~~SE~~ ¼ ~~SW~~ ¼ Sec 29 T 16N N/S R 21 E
PERMIT/WAIVER No. 19,063-01 Parcel No.
Issued by Water Resources

Latitude 39.21563°N
Longitude 119.64724°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8 5/8 WELL		2	90	88
COURSE DG SANDS		90	124	34
BROWN CLAY		124	141	17
FRACTURED DG GRAVELS	XXX	141	190	49

39.215,718°N NAD27 D.D.
119.646,230°W

Date started: 12-Oct, 20 09
Date completed: 13-Oct, 20 09

9. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	90	Feet	190	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.06	.216	70	190
SDR 21				

Perforations:
Type of perforation FACTORY SLOT
Size of perforation 0.032
From 150 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 25 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	45	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SYSTEM INC. (Contractor)
Address # 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Stack (By driller performing actual drilling on site or contractor)
Date 11/03/2009

(Rev. 08-08) USE ADDITIONAL SHEETS IF NECESSARY

STATE ENGINEERS OFFICE
2009 NOV -3 AM 10:57
RECEIVED

No test Method Marked