STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110462
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. (1) 64590

1. OWNER PETE FRIGO
MAILING ADDRESS 2030 FISH SPRINGS RD
SW GARDNERVILLE NV 89410

ADDRESS AT WELL LOCATION 2030 FISH SPRINGS RD
GARDNERVILLE , NV 89410
Subdivision Name: County: Douglas

2. LOCATION ~~NE~~ ¼ SW NW ¼ Sec 6 T 12N N/S R 21 E
PERMIT/WAIVER No. 1221-06-001-004
Issued by Water Resources Parcel No.

Latitude 38.93380°N
Longitude 119.67463°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8 5/8 WELL		+2	90	88
BROWN CLAY		90	134	44
BROWN SILTY SANDS		134	169	35
COURSE DG SANDS AND CLAY SEAMS	XX	169	220	51

New Drilling

38.934°N NAD 27 D.D.
119.674°W

Date started: 19-Jun , 20 09
Date completed: 22-Jun , 20 09

7. Water Level
Static water level: 60 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	25	3 HRS

9. WELL CONSTRUCTION
Depth Drilled 220 ~~190~~ Feet Depth Cased 220 ~~190~~ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 5/8	Inches	90	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.06	.216	80	220
SDR 21				

Perforations:
Type of perforation FACTORY SLOTTED
Size of perforation 0.032
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SYSTEM INC.
Contractor
Address # 20 KIT KAT DRIVE
Contractor
CARSON CITY , NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed
By driller performing actual drilling on site or contractor
Date 06/24/2009

(Rev. 06-06)

USE ADDITIONAL SHEETS IF NECESSARY