FINALIZED MH

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110463
Permit No.
Basin Ø7Ø

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63103

1. OWNER John Sanchez
MAILING ADDRESS 4555 Cross Wind Ave WMCA NV 89445

ADDRESS AT WELL LOCATION 4555 Cross Wind Ave WMCA NV 89445
Subdivision Name: County: Humboldt

2. LOCATION SW ¼ SE ¼ Sec 23 T 35 (N) S R 37 E
PERMIT/WAIVER No. 014-094-06
Issued by Water Resources Parcel No.

Latitude 40.888468°N
Longitude 117.783362°W
NAD 27 (TA)

UTM E 434005 ☒ NAD 27
N 4526453 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	10	10
Sandy Clay		10	40	30
Rocky Clay		40	60	20
Small Gravel Clay		60	80	20
Rocky Clay		80	100	20
Sand & Gravel		100	120	20
Yellow Clay		120	140	20
Rocky Clay		140	160	20
Soft Rocky Clay		160	180	20

RECEIVED 2010 APR 15 AM 11:46 STATE ENGINEERS OFFICE

Date started: 3-10, 2010
Date completed: 3-12, 2010

9. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	180

Perforations:
Type of perforation Torch Cut
Size of perforation 3/16 x 3
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout 5 to 60 ☐ Pumped ☒ Poured
☐ ≥80% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 20 to 180 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 60 to 120 ☐ Pumped ☒ Poured
Type: 3/8

7. Water Level
Static water level: 86 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Rotary	40	UNK	2 Hrs

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LBJ DRILLING & PUMP COMPANY, INC.
Contractor
Address P.O. BOX 902 - Winnemucca, NV 89446
Contractor

Nevada contractor's license number
Issued by the *State Contractor's Board* 0009605A
Nevada driller's license number issued by the
Division of Water Resources, the *on-site driller* 1807

Signed Joe Boggio
By driller performing actual drilling on site or contractor Joe Boggio
Date

USE ADDITIONAL SHEETS IF NECESSARY