

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63152 ①

1. OWNER Keith Aitken ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 7165 Allen Rd. Winnemucca NV. 89445 _____
 2. LOCATION NW 1/4 NE 1/4 Sec 13 T 35 R 37 E Humboldt County _____
 PERMIT NO. _____ Issued by Water Resources Parcel No. 013-541-18 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Gravel, sand</u>				
<u>Cemented Gravel yes</u>		<u>130</u>	<u>240</u>	<u>110</u>
<u>GPS</u>				
<u>N 40° 54.780</u>				
<u>W 117° 45.873</u>				
<u>NAO 27</u>				
<u>40.915° N NAO 27 0.6</u>				
<u>117.265° W</u>				

2009 JUN -4 AM 11:30
 STATE ENGINEER OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)
7 7/8 Inches From 130 Feet To 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>54.840</u>	<u>PVC</u>	<u>120</u>	<u>240</u>

Perforations:
 Type perforation slot
 Size perforation .125
 From 160 feet to 240 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal NA Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 130 feet to 240 feet

Date started 5-9 2009
 Date completed 5-16 2009

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>	<u>NA</u>	<u>3 1/2</u>

9. WATER LEVEL
 Static water level 100 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Firstgold Corp. Contractor
 Address P.O. Box 6 Lovelock NV. Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0071020
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
 Signed Sheldon Amarty
 By driller performing actual drilling on site or contractor
 Date 5-16-09