

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 110516  
Permit No. \_\_\_\_\_  
Basin 177

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63953

1. OWNER Brian Boquest/ICI Cattle & Timber Co. LLC ETAL ADDRESS AT WELL LOCATION South of wells East off highway 93  
MAILING ADDRESS 17080 Butler Hill Rd  
Dallas, OR 97338 Subdivision Name: \_\_\_\_\_ County: Elko

2. LOCATION SW 1/4 NE 1/4 Sec 29 T 36N N/S R 63 E Latitude 40.58.553N UTM E  NAD 27  
PERMIT/WAIVER No. 008-550-015 Longitude 114.52.601 N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	30	30
LIMESTONE		30	80	50
GRAVELY CLAY		80	180	100
GRAVEL		180	220	40
GRAVELY CLAY		220	300	80
LIMESTONE		300	400	100
RED CLAY		400	500	100
GRAVEL		500	620	120
LIMESTONE		620	650	30
RED CLAY/GRAVEL		650	670	20
FRACTURED LIMESTONE		670	740	70
GRAVELY CLAY		740	1040	300

9. WELL CONSTRUCTION

Depth Drilled 1040 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 3/4"</u> Inches	<u>0</u> Feet	<u>50</u> Feet
<u>7 1/2"</u> Inches	<u>50</u> Feet	<u>1040</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
		None		

**NO WATER FOUND**

plugged by well log # 108897  
40.976°N NAD 27 AD  
114.876°W

Perforations:

Type of perforation \_\_\_\_\_  
Size of perforation \_\_\_\_\_

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_  
Bentonite Chips:  Yes  No to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 29-Apr 2009  
Date completed: 6-May 2009

7. Water Level  
Static water level: NONE feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sharel "Clay" Fertig Jr. dba Fertig Drilling Company  
Contractor  
Address P.O. Box 525  
Contractor  
Elko, NV 89803

Nevada contractor's license number  
issued by the State Contractor's Board 031904

Nevada driller's license number issued by the  
Division of Water Resources, the on-site driller 2367

Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 05-25-09

(Rev. 05-09)

USE ADDITIONAL SHEETS IF NECESSARY

MNH-F