WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

(1)

OFFICE USE ONLY
Log No. 110623
Permit No.
Basin 048

NOTICE OF INTENT NO. 64459

1. OWNER John Naunguyan
MAILING ADDRESS 307 N. Spring Valley Pkwy Spring Crk, NV 89815
ADDRESS AT WELL LOCATION Not established 3048 Finch Ave.

2. LOCATION SE ¼ SE ¼ Sec. 15 T. 32 N/S R. 55 E. Elko County
PERMIT NO. N/A Issued by Water Resources | 027-025-005 Parcel No. | Lucky Nugget Ranchoes Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	1
Clay, sand, gravel, boulders		1	3	2
Boulders		3	16	13
Clay		16	82	66
Clay, Sand, gravel	4gpm	82	84	2
Clay (sandy)		84	152	68
Sand		152	171	19
	vvvv			
Clay		171	180	9
40.653°N NAD27 D.D.				
115.761°W				
G.P.S.				
40.65260				
115.76055				
Elev. 5293				

Date started 6-24, 2009
Date completed 7-2, 2009

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
26	2	½

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 181.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	180 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1½	10
10	F-480	SDR17 - 3/8	10	180

Perforations:
Type perforation Mill slots (horizontal)
Size perforation .032
From 150 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 78 feet below land surface
Artesian flow n.a. G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ~~[illegible]~~ MUTH DRILLING CO Contractor
Address 203 PINE ST., ELKO, NV 89801 Contractor

Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed Jane V. Muth By driller performing actual drilling on site or contractor
Date July 4, 2009

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY MM4 (F) (O)-627