WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110027
Permit No.
Basin 049

NOTICE OF INTENT NO. 64456 (1)

1. OWNER ~~Chris~~ CHRISTINA SARGOSA FRAGOZA
MAILING ADDRESS 703 Last Chance Rd #6
Elko, NV 89801
ADDRESS AT WELL LOCATION None established

2. LOCATION SE ¼ SW ¼ Sec. 7 T. 34 N/S R. 56 E. Elko County
PERMIT NO. N/A (Issued by Water Resources) | 032-005-017 (Parcel No.) | Last Chance Ranch Unit #5 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Elko Fm. (tuff)		0	190	190
Sand, gravel, clay	± 1gpm	190	191	1
Elko formation		190	260	69
Quartzite cong. boulders		260	280	20
Clay, sand, gravel	✓	280	294	14
Sand, gravel	✓	294	310	16
Clay		310	315	5
Clay, sand, gravel	✓✓	316	335	19
Clay		335	338	2
40.841°N NAD27		D.D.		
115.712°W				
G.P.S.				
40.84133 N				
115.71306 W				

Date started 9-18, 2009
Date completed 11-6, 2009

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	40	2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 338 Feet Depth Cased 339 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
16 Inches	0 Feet	50 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	339

Perforations:
Type perforation Torch cut
Size perforation
From 258 feet to 278 feet
From 298 feet to 330 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to ~~TD~~ 338 feet

9. WATER LEVEL
Static water level 185 feet below land surface
Artesian flow no G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Muth Drilling Co (Contractor)
Address 203 Pine St, Elko, NV 89801 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James V. Muth (By driller performing actual drilling on site or contractor)
Date 11-10-09

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY MMH (F) (O)-627