STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 100540
Permit No.
Basin 137B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. (1) 64891

1. OWNER Pat and Patsy Waits
MAILING ADDRESS same

ADDRESS AT WELL LOCATION Lott 111 GS,
Gillman Springs, Nevada 89310
Subdivision Name: County: Lander

2. LOCATION SW ¼ NE ¼ Sec 10 T 16N N/S R 44 E
PERMIT/WAIVER No. 004-003-07
Issued by Water Resources Parcel No.

Latitude N39-15-51.3 Longitude W117-00-57.2
UTM E N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	35	
Cream Colored Clay		35	55	
Brown Clay	X	55	120	
Sand Clay and Water	x	120	155	
Gravel & Water	x	155	160	

2009 OCT 26 PM 1:13 STATE ENGINEER'S OFFICE

39.264,250°N NAD27 O.D.
117.015,889°W

Date started: September 25, 20 09
Date completed: 27-Sep 20 09

7. Water Level
Static water level: 20 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9 7/8	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	160

Perforations:
Type of perforation Torch
Size of perforation 1/8 x 6" x 4 times around
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 100 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 100 to 160 ☐ Pumped ☒ Poured
Type: Pea Rock
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista St. (Contractor)
Las Vegas, Nevada 89149
Nevada contractor's license number issued by the *State Contractor's Board* 10062
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date October 23 2009

(Rev. 08-08)
USE ADDITIONAL SHEETS IF NECESSARY

MMH