STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110542
Permit No.
Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64054 (i)

1. OWNER Thomas & Tracy Hamilton
MAILING ADDRESS 5073 Schreiner Dr. Winnemucca, NV

ADDRESS AT WELL LOCATION Brinkerhoff Dev. #1 Lot 20 < of Brinkerhoff & Larry - 4000 Larry Dr.
Subdivision Name: County:

2. LOCATION NE ¼NE¼ Sec12T35N / R37E
PERMIT/WAIVER NO. 013-475-25
Issued by Water Resources Parcel. No.

Latitude N40°.92636 UTM E ☐ NAD 27
Longitude W117°.75766 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	2	2
Course gravel		2	10	8
Clay		10	15	5
cobles & gravel		15	25	10
clay		25	85	60
sand/gravel	X	85	100	15
clay		100	120	20
sand/gravel-w/clay streamers		120	135	15
course sand gravel	X	135	165	30
clay		165	170	5

40.926,457°N NAD27 D.D.
117.756,697°W

Date started: March 4, 20 09
Date completed: March 6, 20 09

7. Water Level
Static water level: 81 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		6

9. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	170 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+1	10
6.625	4.06	.316	10	170

Perforations:
Type of perforation Factory Cut Slots
Size of perforation 050
From 130 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 30 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 170 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 30 to 50 ☐ Pumped ☒ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling Inc
By driller performing actual drilling on site or contractor
Date March 17, 2009

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

MMH-(F)