STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

CORRECTED

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 110545
Permit No.
Basin 101

NOTICE OF INTENT NO. 63760

1. OWNER Brian Bellanger
MAILING ADDRESS 3205 N Park Manor
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 6034 Smokin Bull Rd Ct.
Fallon, NV 89406
Subdivision Name:
County: Churchill

2. LOCATION NW¼NW¼ Sec27T18N/ R28E
PERMIT/WAIVER NO. 006-541-5D
Issued by Water Resources — Parcel. No.

Latitude 39.40155
Longitude -118.83399
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	2	2
Brown Clay		2	13	11
Brown Sand		13	32	19
Gray Sand		32	46	14
Gray Clay		46	70	24
Brown Clay		70	72	2
Brown Sand	X	72	80	8

39.401632°N NAD27 D.D.
118.833,004°W

Date started: 03/13, 20 09
Date completed: 03/13, 20 09

9. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12.25 Inches	0 Feet	50 Feet
10 Inches	50 Feet	80 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	20
6.625PVC	4.1	.316	20	80

Perforations:
Type of perforation Saw Cut
Size of perforation 1/8
From 75 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 10 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 10 to 50 ☒ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 80 to 50 ☐ Pumped ☒ Poured
Type: 3/8
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 7 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		1hr

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling,Inc. (CONTRACTOR)
Address P.O. box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2307
Signed
By driller performing actual drilling on site or contractor
Date 3/27/2009

2009 APR 1 P 12:05

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

MMA - (F)