STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110547
Permit No.
Basin 072

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64053 (1)

1. OWNER Dawn Hart
MAILING ADDRESS 200 State Route 400 Sp# 6 Imlay NV

ADDRESS AT WELL LOCATION 1805 Willow Creek Ranch Rd
Subdivision Name: County: Pershing

2. LOCATION NW¼SW¼ Sec23T32N / R35E
PERMIT/WAIVER NO. 008-490-20
Issued by Water Resources Parcel. No.

Latitude N40°62976 UTM E ☐ NAD 27
Longitude W118°01912 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	1	1
clay		1	6	5
gravel & sand		6	10	4
clay w/gravel		10	75	65
course sand gravel	X	75	114	39
clay		114	116	2
gravel	X	116	120	4

40.629,854°N NAD27 D.D.
118.018,149°W

Date started: Feb 18, 20 09
Date completed: Feb 19, 20 09

7. Water Level
Static water level: 59 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
14		4

STATE ENGINEERS OFFICE
2009 APR 21 AM 10:48
RECEIVED

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	20
6.625 PVC	4.06	.316	20	120

Perforations:
Type of perforation Factory Cut Slots
Size of perforation 050
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	0 to 20	☒ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☒ ≥30% Bentonite Grout	20 to 50	☒ Pumped	☐ Poured
Gravel Pack: ☒ Yes ☐ No	60 to 120	☐ Pumped	☒ Poured
Type:			
Bentonite Chips: ☒ Yes ☐ No	60 to 70	☐ Pumped	☒ Poured
Type:			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling, Inc
By driller performing actual drilling on site or contractor
Date March 9, 2009

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

MMH - (F)