WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110550
Permit No.
Basin 137B

NOTICE OF INTENT NO. 63554 (1)

1. OWNER Taing Tresse
MAILING ADDRESS HC60 Box 378106 Round Mtn NV 89045-9609
ADDRESS AT WELL LOCATION Corner Of Santa Court Lane and Santa Court Drive
2. LOCATION NE ¼ NW ¼ Sec. 9 T. 10 N/S R. 43 E. NYE County
PERMIT NO. Issued by Water Resources
012-451-11 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP Soil		0	15	15
Clay - Boulders		15	70	55
Sand - Boulders	Y	70	100	30
Clay		100	102	2

WGS 84
N 38° 44.722'
W 117° 09.494'

38.745,442°N NAD27 D.D.
117.157,311°W

Date started 3-24-09, 20
Date completed 3-25-09, 20

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1:11

RECEIVED 2009 APR -6 PM 1:11 STATE ENGINEER'S OFFICE

8. WELL CONSTRUCTION
Depth Drilled 102 Feet Depth Cased 102 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	102 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6½	WC	Sch 40	0	102

Perforations:
Type perforation JSW SCY
Size perforation 1/8" x 3"
From 62 feet to 102 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 30'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [ ] No
From 50 feet to 102 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko NV 89017 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed (By driller performing actual drilling on site or contractor)
Date 3-26-09

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY MMH (F) (O)-627