

Hycroft - 0465

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110582
Permit No.
Basin 028

FINALIZED MTH

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63825

1. OWNER Warren Woods-Hycroft Resources & Development
MAILING ADDRESS PO Box 3030 Winnemucca, NV 89446

ADDRESS AT WELL LOCATION 55 miles west of Winnemucca on Jungo Rd.
Subdivision Name: County: Humboldt

2. LOCATION NE of the SW Sec 26 T 35N N/S/R 29 E
PERMIT/WAIVER No. NEV 60013
Parcel No.

Latitude N 40.87652 UTM E
Longitude W 118.70318 N
NAD 27
NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [] Replace [] Recondition
[] Deepen [] Other

4. PROPOSED USE
[] Domestic [] Irrigation [] Test
[] Municipal/Industrial [X] Monitor [] Stock

5. WELL TYPE
[] Cable [] Rotary [] RVC
[] Air [X] Other SONIC

LITHOLOGIC LOG table with columns: Material, Water Strata, From, To, Thickness. Includes handwritten entries for brown oxidized sand, gray/green clay, green/gray sand, etc.

Date started 12-Apr 20 10
Date completed 12-Apr 20 10

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 20 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 25 Feet

CASING SCHEDULE table with columns: Size O.D. (Inches), Weight/Ft. (Pounds), Wall Thickness (Inches), From (Feet), To (Feet). Includes entry for Schd 40 pvc.

Perforations:
Type of perforation pvc schd 40 screen
Size of perforation .020 slot - horizontal
From 10 feet to 20 feet

Annular Seal: [X] Yes [] No
[X] Neat Cement 0 to 5 [] Pumped [X] Poured
[] Cement Grout to [] Pumped [] Poured
[] Concrete Grout to [] Pumped [] Poured
[] >=30% Bentonite Grout to [] Pumped [] Poured

Gravel Pack: [X] Yes [] No 8 to 22 [] Pumped [X] Poured
Type: #3 Monterey Sand
Bentonite Chips: [X] Yes [] No 22 to 25 [] Pumped [X] Poured
Type: 5ft-8ft (3ft) gout seal - 3/8" Bentonite Hole Plug

7. Water Level
Static water level: 7 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear
Contractor

Address 3894 Railroad Ave., Yuba City, CA 95991
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2234

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 4/27/2010

8. WELL TEST DATA table with columns: TEST METHOD (Bailer, Pump, Air Lift), G.P.M., Draw Down (Feet Below Static), Time (Hours). Includes a stamp from the State Engineers Office dated 02:11 PM 4-26-10.