

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 110594  
Permit No. \_\_\_\_\_  
Basin 101 pg/10/2

FINALIZED MMH

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64376

1. OWNER City of Fallon ADDRESS AT WELL LOCATION 16 North Main St  
MAILING ADDRESS 55 E. Williams Ave. Fallon Nevada 89407 Fallon Nevada  
Subdivision Name: \_\_\_\_\_ County: Churchill

2. LOCATION SE 1/4 SW 1/4 Sec 30 T 19 N R 29 E Latitude N 39.77499° UTM E  NAD 27  
PERMIT/WAIVER No. FA# 5-0000174 01-541-01 Longitude W-113.77637 N  NAD 83/WGS 84

Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Stock  
 Municipal/Industrial  Monitor

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>silts clays</u>	<u>NO</u>	<u>0</u>	<u>5</u>	<u>5</u>
<u>silts</u>	<u>Yes</u>	<u>5</u>	<u>10</u>	<u>5</u>
<u>silts sands</u>	<u>Yes</u>	<u>10</u>	<u>15</u>	<u>5</u>
<u>sands gravel</u>	<u>Yes</u>	<u>15</u>	<u>20</u>	<u>5</u>
<u>sands</u>	<u>Yes</u>	<u>20</u>	<u>25</u>	<u>5</u>
<u>MW-10</u>				

NAD 27 GPS  
39.475072° N  
113.775385° W

Site ID:  
# MW-10

9. WELL CONSTRUCTION

Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>12</u>	<u>0</u>	<u>25</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>sch. 40</u>	<u>0</u>	<u>6</u>

Perforations:

Type of perforation Factory slot  
Size of perforation .020

From	feet to	feet
<u>0</u>	<u>25</u>	

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout 0 to 3  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 5 to 25  Pumped  Poured  
Type: 10/20 silica sand  
Bentonite Chips:  Yes  No 3 to 5  Pumped  Poured  
Type: 3/8 Bentonite chips

Date started: April 3rd 20 10  
Date completed: April 3rd 20 10

7. Water Level

Static water level: 9 feet below land surface  
Artesian Flow: NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water Temperature: 68.5 °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE  
2010 MAY -5 AM 11:03  
RECEIVED

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Haz-Tech Drilling, Inc. Contractor  
Address P.O. Box 940 Contractor  
Meridian, Id. 83680

Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 0038018  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller David  
M. 18037-1 Gonzales  
Signed: David Gonzales # 2412  
By driller performing actual drilling on site or contractor  
Date 4/25/10

(Rev. 06-09)

USE ADDITIONAL SHEETS IF NECESSARY

PD-I

LOG# 110594  
pg 2 of 2

To: Nevada State Engineer

NOI # 64376 shows number of wells to be drilled was two. We only drilled one new well (mw-10).

The other well was going to be a overdrill of a existing 2" diameter and replaced as a 4" diameter well but there was a sewer line within 4" of the well and Raz-Tech declined to up size hole diameter. So we only drilled 1 new well under

NOI 64376

Scott L

M-1803

Info ONLY