FINALIZED MAA

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110601
Permit No.
Basin 179

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65316

1. OWNER Robinson NV. Mining RP10-04
MAILING ADDRESS PO Box 382
Ruth, NV. 89319

ADDRESS AT WELL LOCATION Murray Springs, Ely
Subdivision Name: County: White Pine

2. LOCATION NW¼NE¼ Sec29T16N/ R63E
PERMIT/WAIVER NO. M/O-1619 (Issued by Water Resources) Parcel. No.

Latitude Longitude
UTM E 680821 ☒ NAD 27
N 4343716 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	30	30
Alluvium		30	135	105
Brown Limestone		135	370	235
Grey Limestone		370	605	235
Dark Brown Limestone		605	715	110
Brown Limestone		715	820	105
Brown to Grey Marble		820	890	70
Grey Clay		890	900	10
NAD 27 GPS				
39.225794°N				
114.905273°W				
Hole was abandoned				
See Details				

Date started: March 4, 20 10
Date completed: March 8, 20 10

7. Water Level
Static water level: 128 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: Cool °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
225	N/A	3

9. WELL CONSTRUCTION
Depth Drilled 900 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12.25 Inches	0 Feet	140 Feet
6.50 Inches	140 Feet	900 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type of perforation
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 40 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ =30% Bentonite Grout 120 to 900 ☒ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 40 to 120 ☒ Pumped ☐ Poured
Type: 3/8 Hole Plug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave. (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the ~~on-site driller~~ 2350
Signed
By driller performing actual drilling on site or contractor
Date April 27, 2010

STATE ENGINEER
MAY 05 2010
FACSIMILE RCVD

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

Original recieved 4/30/2010 returned for correction.

20-I