

FINALIZED *MA*

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110621
Permit No. _____
Basin 071

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62504

1. OWNER Blazer Mobil homes (Tiffany)
MAILING ADDRESS 3245 fountain way
Winnemucca, Nv 89445

ADDRESS AT WELL LOCATION Thomas cyn & Cattle way 4365 E Thomas Cyn Rd
Winnemucca, Nv 89445
Subdivision Name: Sonomo Ranch County: Humboldt

2. LOCATION SE 1/4 Sec 12 T 35n N/S R 37 E
PERMIT/WAIVER No. 0 Parcel No. 010-483-23

Latitude 40 54.964n UTM E NAD 27
Longitude 117 45.366w N X NAD 83/95/84

3. WORKED PERFORMED
 New Well Replace Recondition
Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
Municipal/Industrial Monitor Stock

5. WELL TYPE
Cable Rotary RVC
Air Other

8. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand		0	5	5
cobbles, gravel, sand & clay		5	50	45
Clay & gravel		50	80	30
cobbles, gravel & sand		80	85	5
gravel & clay		85	105	20
Fractured rock - lost circulation	X	105	230	125
Water bearing frac rock	X	230	270	40
		270	-270	

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
<u>270</u>		<u>270</u>	

HOLE DIAMETER (BIT SIZE)

	From	To	Feet	Feet
<u>10 7/8</u>	<u>0</u>	<u>270</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/FL (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.376</u>	<u>STEEL</u>	<u>.188</u>	<u>0</u>	<u>20</u>
<u>6.900</u>	<u>PVC</u>	<u>sdr21=.450 in</u>	<u>20</u>	<u>270</u>

Date started: 11/1/2008
Date completed: 11/15/2008

Perforations:

Type of perforation	Size of perforation	From	To	Feet	Feet
<u>PVC Screen</u>	<u>1/16</u>	<u>210</u>	<u>270</u>		

Annular Seal: Yes

Neat Cement	to	Pumped	Poured
Cement Grout	<u>4</u> to <u>58</u>	Pumped	<input checked="" type="checkbox"/> Poured
Concrete Grout	to	Pumped	Poured
≥30% Bentonite Grout	to	Pumped	Poured

Gravel Pack: Yes No 60 to 270 Pumped Poured

Type: 3/8 minus

Bentonite Chips: Yes No 58 to 60 Pumped Poured

Type: 3/8 barold

7. Water Level
Static water level: 173 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: COLD °F
Quality: _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name High Desert Drilling LLC
Contractor

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift x

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>15</u>	<u>50</u>	<u>4</u>

Address 4225 E Mary Way
Contractor
Winnemucca Nevada 89445
Nevada contractor's license number 62237
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 2140
Signed [Signature] # 2364
By driller performing the drilling on site or contractor
Date 12-10-08

(Rev. 05-09) USE ADDITIONAL SHEETS IF NECESSARY

STATE ENGINEERS OFFICE
2008 DEC 17 AM 10:55
REC-11

PLO - I