STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110667
Permit No.
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

P-2F 09 37

NOTICE OF INTENT NO. 65223

1. OWNER Klein felder
MAILING ADDRESS 4835 hongley lane
Reno NV 89502

ADDRESS AT WELL LOCATION P-2F 09 37
Marietta Way Washoe
Subdivision Name: County:

2. LOCATION NW ¼ NE ¼ Sec 17 T 19 0 N/S R 20 0
PERMIT/WAIVER No. MO-1558
Issued by Water Resources
Parcel No.

Latitude
Longitude
034-112-42

UTM E 262964.83 86 ☒ NAD 27
N 4377710 ☐ NAD 83/WGS 84
.422

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand w Gravel and Clay (SP-GC)		0	2	
Sandy Silt (ML)		2	6	
Gravel w Sand and Silt (GP-GM)		6	11	
Gravel w Sand and Clay (GP-GC)		11	16	
Gravel with Sand (GP)		16	30	
Gravel with Sand and Clay GP-GC		30	50	
Clayey Gravel w Sand (GC)		50	59.5	

RECEIVED
2010 APR -5 AM 11:58
STATE ENGINEERS OFFICE

NAD 27 GPS
39.520948°N
119.757340°W

Date started: 12-15, 20 09
Date completed: 12-15, 20 09

9. WELL CONSTRUCTION
Depth Drilled 59.5 Feet Depth Cased 21 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	0	Feet	59.5	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		sch 80	0	5

Perforations:
Type of perforation Slot
Size of perforation 020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☒ Neat Cement 0 to 1 ☒ Pumped ☐ Poured
☐ Cement Grout 21 to 59.5 ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 3 to 21 ☐ Pumped ☒ Poured
Type: #3
Bentonite Chips: ☒ Yes ☐ No 1 to 3 ☐ Pumped ☒ Poured
Type: 3/8 Chips

7. Water Level
Static water level: 9.24 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 9.6 °F
Quality: PH. 7.50 EC 436.6

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	-1	NA	2gal 5 low

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration
Contractor
Address PO Box 141 Zamora CA
Contractor
95698
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2111
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 3-22-10

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

PLO-I
MMH-F

(NSPO 3-08)
(O) 627