

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110695
Permit No. _____
Basin φ7φ

FINALIZED MF

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64378

1. OWNER Pilot Travel Centers, LLC ADDRESS AT WELL LOCATION 5625 West I-80
MAILING ADDRESS 5508 Longs Rd Winnemucca, NV 89445
Knoxville, TN 37909 Subdivision Name: _____ County: Humboldt

2. LOCATION NE 1/4 NE 1/4 Sec 9 T 35 R 37 E Latitude N. 40.43064° UTM E NAD 27
PERMIT/WAIVER No. FACT000-212 013-081-04 Longitude W. 117.80566° N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>silt gravel</u>	<u>NO</u>	<u>0</u>	<u>5</u>	<u>5</u>
<u>silt</u>	<u>NO</u>	<u>5</u>	<u>10</u>	<u>5</u>
<u>silt sand gravel</u>	<u>YES</u>	<u>10</u>	<u>15</u>	<u>5</u>
<u>sand gravel</u>	<u>YES</u>	<u>15</u>	<u>20</u>	<u>5</u>
<u>sand</u>	<u>YES</u>	<u>20</u>	<u>30</u>	<u>10</u>
<u>MS-7</u>				

9. WELL CONSTRUCTION

Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
<u>8</u> Inches	<u>0</u> Feet	<u>30</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>SCH. 40</u>	<u>0</u>	<u>25</u>

Perforations:

Type of perforation Factory Slot
Size of perforation .020

From	feet to	feet	feet
<u>25</u>	<u>30</u>		

Annular Seal: Yes No

<input type="checkbox"/> Neat Cement	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Cement Grout	<u>0</u> to <u>20</u>	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack: Yes No 23 to 30 Pumped Poured
Type: 10/20 silica sand

Bentonite Chips: Yes No 20 to 23 Pumped Poured
Type: 3/8 coated pellets

Date started: April 9th, 2010
Date completed: April 9th, 2010

7. Water Level

Static water level: 14 feet below land surface
Artesian Flow: NO G.P.M. _____ P.S.I. _____
Water Temperature: <85 °F
Quality: _____

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED
2010 MAY -5 AM 10:40
STATE ENGINEERS OFFICE

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HAZ-Tech Drilling, Inc. Contractor
Address P.O. Box 940 Contractor
Meridian, Id 83680
Nevada contractor's license number _____
issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller m-18037-1

Signed Walter Stovall
By driller performing actual drilling on site or contractor
Date 4/25/10