

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 110701  
Permit No. \_\_\_\_\_  
Basin 070

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 04378

1. OWNER Pilot Travel Centers, LLC  
MAILING ADDRESS 5508 Lonas Rd  
Knoxville, TN 37909

ADDRESS AT WELL LOCATION 5625 West I-80  
Winnemucca, NV 89445  
Subdivision Name: \_\_\_\_\_ County: Humboldt

2. LOCATION NE 1/4 NE 1/4 Sec 10 T 35 N/S R 37 E  
PERMIT/WAIVER No. FAC 5-000212 013-081-04  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude N 40.93048° UTM E  NAD 27  
Longitude W 117.80593° N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>silt</u>	<u>NO</u>	<u>0</u>	<u>5</u>	<u>5</u>
<u>silt Gravel</u>	<u>NO</u>	<u>5</u>	<u>10</u>	<u>5</u>
<u>silt Sand Gravel</u>	<u>YES</u>	<u>10</u>	<u>15</u>	<u>5</u>
<u>sand Gravel</u>	<u>YES</u>	<u>15</u>	<u>20</u>	<u>5</u>
<u>sand</u>	<u>YES</u>	<u>20</u>	<u>25</u>	<u>5</u>
<u>VE-5</u>				

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
<u>25</u>		<u>25</u>	

  

HOLE DIAMETER (BIT SIZE)			
From	To	From	To
<u>12</u> Inches	<u>0</u> Feet	<u>25</u> Feet	<u>25</u> Feet

  

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>SCH. 40</u>	<u>0</u>	<u>10</u>

  

Perforations:

Type of perforation Factory slot  
Size of perforation .020

From	feet to	From	feet to
<u>10</u>	<u>25</u>		

  

Annular Seal:  Yes  No

<input type="checkbox"/> Neat Cement	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Cement Grout	<u>0</u> to <u>6</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack:  Yes  No 0 to 25  Pumped  Poured  
Type: 1/2 silica sand

Bentonite Chips:  Yes  No 0 to 8  Pumped  Poured  
Type: 3/8 Bentonite Chips

Date started: April 10th 2010  
Date completed: April 10th 2010

7. Water Level  
Static water level: 14 feet below land surface  
Artesian Flow: NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water Temperature: 28.5 °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
G.P.M.	Draw Down (Feet Below Static)		Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HAZ-Tech Drilling, Inc. Contractor  
Address P.O. Box 940 Contractor  
Meridian, Id 83680  
Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 0038018  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller W-18037-1

Signed David Gonzalez  
By driller performing actual drilling on site or contractor  
Date 4/25/10