

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110717
Permit No. _____
Basin 070

FINALIZED MA

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64379

1. OWNER Pilot Travel Centers, LLC ADDRESS AT WELL LOCATION 5625 West I-80
MAILING ADDRESS 5508 Longs Rd Winnemucca, NV. 89445
Knoxville, TN. 37909 Subdivision Name: _____ County: Humboldt

2. LOCATION SW 1/4 SW 1/4 Sec 3 T 35 R/SR 37 E Latitude N 40.931116 UTM E NAD 27
PERMIT/WAIVER No. FACT 5-000212 013-091-04 Longitude W 117.804479 N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------|--------------|----------|-----------|------------|
| <u>well materials</u> | <u>0</u> | <u>0</u> | <u>25</u> | |
| <u>over drill</u> | | | | |
| <u>2" - 4"</u> | <u>14</u> | | | |
| <u>mw-2</u> | | | | |

9. WELL CONSTRUCTION

Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From | To | Feet | Feet |
|------------|----------|-----------|------|------|
| <u>12'</u> | <u>0</u> | <u>25</u> | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>4</u> | | <u>sch. 40</u> | <u>0</u> | <u>10</u> |

Perforations:

Type of perforation Factory slot
Size of perforation .028

| From | feet to | feet |
|-----------|-----------|------|
| <u>10</u> | <u>25</u> | |

Annular Seal: Yes No

Neat Cement to - Pumped Poured
 Cement Grout 0 to 6 Pumped Poured
 Concrete Grout to Pumped Poured
 ≥30% Bentonite Grout to Pumped Poured

Gravel Pack: Yes No 8 to 25 Pumped Poured
Type: 10/20 silica sand

Bentonite Chips: Yes No 6 to 8 Pumped Poured
Type: 3/8 Bentonite chips

Date started: April 8th, 20 10
Date completed: April 8th, 20 10

7. Water Level

Static water level: 14 feet below land surface
Artesian Flow: NO G.P.M. _____ P.S.I. _____
Water Temperature: 25.5 °F
Quality: _____

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| | | |

STATE ENGINEERS OFFICE
2010 MAR - 5 AM 11:03
RECEIVED

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Haz-Tech Drilling, Inc. Contractor
Address P.O. Box 940 Contractor
Meridian, Id. 83680
Nevada contractor's license number _____
issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller m-18037-1

Signed Daniel Gonzalez
By driller performing actual drilling on site or contractor
Date 4/25/10