110725

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. [redacted]
Permit No.
Basin

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4445

1. OWNER PREFERRED EQUITIES CORP
MAILING ADDRESS P.O. BOX 220 PAHRUMP, NEV.
ADDRESS AT WELL LOCATION NORTH OF MANGE

2. LOCATION N.E. ¼ S.E. ¼ Sec. 6 T. 21 N/S R. 54 E. NYE County
PERMIT NO. Issued by Water Resources Parcel No. UNIT 12 Subdivision Name

3. TYPE OF WORK Plug
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	9	9
HARD BROWN CLAY		9	14	5
HARD GREEN CLAY		14	17	3
HARD WHITE CALECHE		17	33	16
HARD BROWN CALECHE		33	37	4
BROWN CALECHE		37	67	30
HARD BROWN CALECHE		67	74	7
BROWN CLAY		74	81	7
WHITE CALECHE		81	89	8
HARD BROWN CALECHE		89	91	2
BROWN CALECHE		91	111	20
HARD BROWN CALECHE		111	113	2
BROWN CLAY		113	117	4
HARD BROWN CALECHE		117	123	6
GREY CALECHE		123	149	26
HARD BROWN CALECHE		149	161	12
BROWN CLAY		161	170	9
HARD BROWN CALECHE		170	180	10

THIS WELL TESTED HIGH TDS AND HIGH SULFIDES.

WELL ABANDONED WITHOUT CASING.
PLUGGED WITH NEAT CEMENT FROM -5 FT. TO 180 FT. THEN NATIVE SOIL FROM 0 TO 5 FT.

Date started 9-23, 1987
Date completed 10-4, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1 HP	20	1 FT.	3

RECEIVED
NOV 24 1987
Div. of Water Resources
Brunell Office - Las Vegas, NV

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 180 feet
Casing record NONE
Weight per foot — Thickness —

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 45 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality HIGH TDS - HIGH SULFIDES

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RON FLOYD PUMP & DRILLING
Contractor
Address BOX 157 PAHRUMP, NEV. 89041
Contractor
Nevada contractor's license number 7479-A
Nevada contractor's drillers number 1424
Nevada driller's license number 1427 - STAN HARDIN
Actual Driller
Signed [signature] 1424
Contractor
Date 10-14-87

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) D-627 CR434

Log for well plugging