STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110727
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63984

1. OWNER Rene Maria Rene
MAILING ADDRESS 441 Mountain Villa Dr
Las Vegas NV 89110

ADDRESS AT WELL LOCATION 1550 N. Rancho Dr
Las Vegas NV
Subdivision Name: Twin Lakes Village County: Clark

2. LOCATION NW ¼ NW ¼ Sec 29 T 20 N/S R 61 E
PERMIT/WAIVER No. 09-29-102-120 Issued by Water Resources
8-000031 Parcel No.

Latitude 36° 11' 18"
Longitude 115° 11' 07"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silts w/ Gravel		0	9	9'
Silty w/ Caliche Layers	X	9	18	9'
Silts & Clays		18	31	
MW-9				

RECEIVED
FEB 22 2010
LAS VEGAS OFFICE

Date started: 10-6, 20 09
Date completed: 10-6, 20 09

9. WELL CONSTRUCTION
Depth Drilled 31 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	31	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.5	Sch 40 PVC	.25	0	10

Perforations:
Type of perforation Machine Slotted PVC
Size of perforation 0.020"
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement 0 to 5 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 8 to 31 ☐ Pumped ☒ Poured
Type: #3 Sand
Bentonite Chips: ☒ Yes ☐ No 5 to 8 ☐ Pumped ☒ Poured
Type: 1/4" Chips

7. Water Level
Static water level: 15 feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: NA °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	NA	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Yellow Jacket Drilling Services LLC (Contractor)
Address P.O. Box 501, Gilbert Az 85299 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0058304 - A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1817
Signed (By driller performing actual drilling on-site or contractor)
Date 10.12.09

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY