WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

(P) M4

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110802
Permit No. –
Basin 207

NOTICE OF INTENT NO. 59940

1. OWNER David Lewis
MAILING ADDRESS 1465 Morning Sun Way
Las Vegas, NV 89110

ADDRESS AT WELL LOCATION 135 S. Preston Ave.
WBS N 38° 54.410'
W 115° 03.764'

2. LOCATION NW ¼ NE ¼ Sec. 13 T. 12 N/S R. 61 E White Pine County
PERMIT NO. N/A Issued by Water Resources
13-012-08 Parcel No.
Preston Five Acre Plat Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Clay top Soil		0	3	
Silty clay		3	7	
Cobbles gravel - clay		7	45	
Clay		45	67	
Soft tan Sandstone		67	71	
tan Sand Stone	water	71	76	5
Soft tan Sand Stone		76	87	
tan Sand Stone		87	92	
Sand redish. Brown	water	92	97	5
" " "	water	97	104	7
tan Sand Stone		104	110	
Harder Sand Stone	water	110	112	2
Sand Stone		112	121	
Brown Silty Clay		121	127	
tan gravel clay	water	127	150	

NAD 27 GPS
38.906891° N
115.061882° W

Date started Jan 8, 2010
Date completed Feb 13, 2010

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	4	1hr

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	150

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.9	.188	-18"	10.5
6		Sch 40 PVC	10.5	150

Perforations:
Type perforation Factory
Size perforation .032
From feet to feet
From 110 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Maynard Well Drilling Contractor
Address PO Box 64 Lund, NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 047226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Owen Maynard By driller performing actual drilling on site or contractor
Date Feb 20 - 2010

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 12-01) (O)-627