STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

(F) M4

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110803
Permit No. –
Basin 092A

NOTICE OF INTENT NO. 64067

1. OWNER Travis Bonnano
MAILING ADDRESS 10165 Shenandoah Dr.
Reno, NV 89508

ADDRESS AT WELL LOCATION 10065 Laurent Drive
Reno, NV
Subdivision Name: County: Washoe

2. LOCATION SE ¼ NE ¼ Sec 13 T 21N N/S R 18 E
PERMIT/WAIVER No. 086-260-17
Issued by Water Resources Parcel No.

Latitude 39 41.384
Longitude 119 54.377
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand and clay		0	10	10
sand		10	17	7
sand and clay		17	53	36
dg		53	143	90
clay		143	172	29
sand and clay		172	242	70
dg	x	242	261	19
clay	x	261	265	4
dg	x	265	280	15

NAD-27 GPS
39.689825°N
119.905254°W

Date started: 4-Feb, 20 10
Date completed: 10-Feb, 20 10

7. *Water Level*
Static water level: 140 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8	10	3
15	35	
30	60	
30+	140	

9. *WELL CONSTRUCTION*
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	60	Feet
8 3/4	Inches	60	Feet	280	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.97	.188	+18"	280

Perforations:
Type of perforation factory mill slot
Size of perforation 3/32"
From 240 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 55 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 55 to 280 ☐ Pumped ☒ Poured
Type: 1/4" pea gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling, Inc
Contractor
Address 4850 Joule St. A5, Reno NV 89502
Contractor
Nevada contractor's license number issued by the *State Contractor's Board* 14170
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2121
Signed
By driller performing actual drilling on site or contractor
Date 2/10/2010

(Rev. 06-08)

USE ADDITIONAL SHEETS IF NECESSARY

PLD-I