STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110821
Permit No. —
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60745

1. OWNER Marty Wright
MAILING ADDRESS 215 Mott Court GV NV

ADDRESS AT WELL LOCATION 215 Mott Court
Gardnerville, NV
Subdivision Name: County: Douglas

2. LOCATION SW ¼ NW ¼ Sec 3 T 12N N/S R 19 E
PERMIT/WAIVER No. 1219-03-001-033 Issued by Water Resources
Parcel No.

Latitude 38 56.078' Longitude 119 50.577'
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay & Sand		0	11	11
Brown sand		11	26	15
Cobbles		26	70	44
Solid Brown Clay		70	110	40
Fractured Granite	X	110	140	30
Solid Granite		140	218	78
Fractured Granite	X	218	250	32

GPS NAD-27
38.934726° N
119.841938° W
Replaces WL#64656

Date started: 2-Feb, 20 10
Date completed: 5-Feb, 20 10

7. Water Level
Static water level: 42 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		3.5

9. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	250	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	250

Perforations:
Type of perforation factory milled
Size of perforation 3/32" X 3"
From 115 feet to 135 feet
From 230 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 52 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 52 to 250 ☐ Pumped ☒ Poured
Type: 3/8 washed pea gravel
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blain Drilling (Contractor)
Address PO Box 1255 CC NV 89702 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 46498
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2167
Signed (By driller performing actual drilling on site or contractor)
Date 2/25/2010

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 06-08)

PLO.-I
(F)