WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

Finalized MH

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110824
Permit No.
Basin 070

NOTICE OF INTENT NO. 47575 (i)

1. OWNER Allied General
MAILING ADDRESS 1220 E. Olive Ave.
Fresno CA 93728

ADDRESS AT WELL LOCATION Lot 24
6285 Rosecreek Hwy.
Winnemucca NV. 89445

2. LOCATION SW ¼ SE ¼ Sec. 9 T. 35 N/S R. 37 E. Humboldt County
PERMIT NO. ____ Issued by Water Resources | 13-065-07 Parcel No. | Broken Arrow Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	4	4
Clay		4	75	71
Cemented Sand & Gravel	75	75	140	65

GPS N 40° 55.172
W 117° 49.221
NAD 27

40.919, 533°N NAD 27 O.D.
117.820, 350°W

Date started 6-21, 2008
Date completed 6-23, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	NA	4 hours

STATE ENGINEER'S OFFICE
2008 JUL -9 AM 10:24
RECEIVED
2008 JAN 27 AM 11:23

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 140 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188 Steel	0	10
6 5/8	Sched 40	PVC F480	10	140

Perforations:
Type perforation Hand Cut
Size perforation 5/8" x 3"
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 72 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Firstgold Corp. (Contractor)
Address 1055 Cornell P.O. Box 6 (Contractor)
Lovelock NV. 89415
Nevada contractor's license number issued by the State Contractor's Board 007102 7102C
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed [signature]
By driller performing actual drilling on site or contractor
Date 7-3-08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627