Finalized MH

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110832
Permit No.
Basin 094

NOTICE OF INTENT NO. 49854 (i)

1. OWNER Jeff Laughlin
MAILING ADDRESS 8043 Mass Creek Reno, NV 89506

ADDRESS AT WELL LOCATION 15075 Graham Ln.
Reno, NV. 89506
Subdivision Name: N/A County: Washoe

2. LOCATION SW¼~~SW~~SE Sec7T22n/ R19E
Latitude 39° 47' 00.35" N UTM E ☐ NAD 27
Longitude 119° 53' 29.10" W N ☒ NAD 83/WGS 84

PERMIT/WAIVER NO. N/A (Issued by Water Resources) 079-372-08 (Parcel. No.)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	32	32
Brown Clay Stone		32	35	3
Sand		35	125	90
Gray Clay		125	134	9
Gray Sand Stone		134	171	37
Gray Shell		171	192	21
Gray Sand Stone		192	198	7
DG		198	225	48
Brown Clay Stone		225	231	6
DG		231	238	7
Brown Clay Stone		238	245	3
DG		245	247	2
Brown Clay Stone		247	248	1

39.783,523°N NAD27 D.D.
119.890,388°W

Date started: 6-1, 20 05
Date completed: 6-2, 20 05

7. Water Level
Static water level: 81 feet below land surface
Artesian Flow: None G.P.M. None P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	30	240	1 hr.

9. WELL CONSTRUCTION
Depth Drilled 248 Feet Depth Cased 248 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	248 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8 Steel	17	.250	-1	09
6 5/8 PVC	4.95	.390"	09	248

Perforations:
Type of perforation Mill Slot
Size of perforation .030
From 208 feet to 228 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 248 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Miller & Son's Drilling (CONTRACTOR)
Address P.O. Box 8056 (CONTRACTOR)
Reno, NV. 89507
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 6-3-08 (Revised Log)

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com