WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

Finalized MH

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 110834
Permit No.
Basin 069

NOTICE OF INTENT NO. 47582 (i)

1. OWNER Pauline Lambert
MAILING ADDRESS 4085 Lambert Dr. Winnemucca NV. 89445
ADDRESS AT WELL LOCATION 10000 Indian Court Winnemucca NV. 89445

2. LOCATION NE ¼ NE ¼ Sec. 21 T. 37 N/S R. 38 E. Humboldt County
PERMIT NO. (Issued by Water Resources) 0651121 (Parcel No.) Lambert (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP Soil		0	5	5
Clay	50	5	60	55
Sand, Gravel	40	60	100	40
GPS				
N 41° 04.577				
W 117° 41.850				
NAD 27				
41.076, 283°N	NAD 27 O.D.			
117.697, 500°W				

2008 SEP 11 PM 12:59

Date started 8-15, 2008
Date complated 8-20, 2008

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	NA	4

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	100 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	PVC	Sched 40	10	100
6 5/8	Steel	.188	0	10

Perforations:
Type perforation Hand Cut
Size perforation ¼ x 6
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Firotgold Corp. (Contractor)
Address 1055 Cornell P.O. Box 6 (Contractor)
Lovelock NV. 89419
Nevada contractor's license number issued by the State Contractor's Board 0071020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2032
Signed Harold Moritz
By driller performing actual drilling on site or contractor
Date 8-20-08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627